

- A. Shut off all sources of ignition such as electronic igniters, pilot lights, burners, electric appliances prior to the filling of any LP-Gas tanks or containers.
- B. Shut down internal combustion engines within 15 feet of the point of transfer.
- C. Point of transfer must be 15 feet away from open flames, smoking metal cutting, welding, portable electrical tools and extension lights capable of igniting LP-Gas.
- D. Keep a minimum of 25' distance between point of transfer and exposures. (Exposures are other recreational vehicles, travel trailers, box trailers, tents, mobile homes, modular homes, park models and sheds.)
- E. At all times maintain a 20' minimum unobstructed clearance access for Fire Department apparatus and emergency services. During the unloading or transfer of LP-Gas, the tank truck shall be located or parked clear of a public thoroughfare.

