

**510.1 Identification:** Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements, shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed, and readily visible.

### **Fire Protection Equipment Room Identification**

When any fire protection system or system component is located in a room, closet, or other enclosed space, the outside of the door shall have a sign identifying the system or component.

Letters shall be at least two (2) inches in height in a color that is contrasting to the door color.

Some examples are:

“Fire Alarm Panel”

“FACP”

“Fire Command Center”

“Fire Sprinkler Riser”

“Fire Riser Room”

*Applicant shall verify that the proposed signage shall meet all applicable requirements for ADA and the visually impaired.*



**MESA FIRE  
DEPARTMENT  
DETAIL  
FPD 510.1**

**Fire Protection Equipment  
Room Identification**

**Issued:  
07/14/2011**

**FPD 510.1  
Page 1 of 1**